

# VOC Content Test Certificate

Friday 04<sup>th</sup> October 2019

Supplier: Laticrete Pty Ltd (29 Telford Street, Virginia, QLD, 4014, Australia).

Sample Description: LATICRETE<sup>®</sup> 226 Thick Bed Mortar

Date Tested: July 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

|   |  |
|---|--|
| <p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia</b><br/><b>Green Star Design &amp; As Built V1.2-13.1.1B</b><br/><b>Green Star Interiors V1.2-12.1.1B</b></p>         | <p align="center"><b>LATICRETE<sup>®</sup> 226 Thick Bed Mortar</b></p>    |
| <p align="center"><b>General Purpose Adhesives: 50 grams per Litre</b></p>  | <p align="center"><b>2 grams per Litre as VOC content per material</b></p> |
| <p align="center"><i><b>We hereby certify LATICRETE<sup>®</sup> 226 Thick Bed Mortar is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</b></i></p> |  |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Luke Morley  
BSc (Tech)  
Consultant

V1907025A