

# VOC Content Test Certificate

Thursday April 19<sup>th</sup>, 2012

Manufacturer: Laticrete Pty Ltd (29 Telford St, Virginia, QLD 4014)

Sample Description: Laticrete Permacolor Grout

Date Tested: April 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b></p>	<p align="center"><b>Laticrete Permacolor Grout</b></p>
<p>Any solvent based coating whose purpose is not covered in table</p> <p>200 grams per Litre as VOC content per material</p>	<p><b>8 grams per Litre as VOC content per material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Anne Saletti  
BNanotech/BSc(Hons)  
Consultant

CV120411