

# VOC Content Test Certificate

Thursday 17<sup>th</sup> December 2020

Supplier: Laticrete Pty Ltd (29 Telford Street, Virginia, QLD, 4014, Australia).

Sample Description: LATICRETE® HYDRO BAN®

Date Tested: December 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b>  <b>Green Star Interiors V1.3-12.1.1B</b>	<b>LATICRETE®</b>  <b>HYDRO BAN®</b>
<b>Water Proofing Membranes: 250 grams per Litre</b>	<b>2 grams per Litre as VOC content per material</b>
<p><i>We hereby certify that LATICRETE® HYDRO BAN® is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
PhD (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotech)  
Senior Consultant

V2012001