

LABORATORY REPORT

Report Date: 11/1/11

Customer: HP Spartacote, LLC

810 Brickyard Circle #1

Golden, Colorado 80403

Customer Contact: Sean Shiers

(Sean.Shiers@hpspartacote.com)

TEST PANELS:

Received 10/27/11

Lab ID	Description
1045	1. 3 Coat - Solid - w/Clear
1046	2. Full Chip System
1047	3. Quartz

TESTING:

ASTM D 2240 Durometer Hardness

Type: Shore D

Hand held (manual) tester

Results:

Lab ID	Description	Hardness
1045	1. 3 Coat - Solid - w/Clear	94
1046	2. Full Chip System	80
1047	3. Quartz	74

Testing reviewed by: